

**CERTIFICATE OF CALIBRATION**  
**DIFFERENTIAL PRESSURE TRANSMITTER**

Certificate No. : 0479-26-HI-CAL-10

**Customer Information**

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

**Instrument Information**

KKS No. 60LCA54CP005  
Instrument Description CONDENSATE BOOSTER PUMP OUTLET WATER PRESSURE 1  
Manufacture YOKOGAWA  
Model / Serial Number EJX430A / 91V703384  
Instrument Location TURBINE 1ST FLOOR

Range 0 ~ 50  
Unit bar g  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 28-05-2026

**Environment Condition**

Temperature 31 °C Humidity 65 % RH

**Calibration Result**

| Data Reading (Transmitter) |            |            |           |        |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |        |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [bar g]                    | [mA]       | [mA]       |           | [%]    |        | [bar g] | [mA]       | [mA]       |           | [%]   |        |
| 0.000                      | 4.000      | 4.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 12.500                     | 8.000      | 8.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 25.000                     | 12.000     | 12.000     | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 37.501                     | 16.000     | 16.000     | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 50.001                     | 20.000     | 19.999     | -0.001    | -0.006 | Pass   |         |            |            |           |       |        |
| 37.501                     | 16.000     | 16.000     | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 25.000                     | 12.000     | 12.000     | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 12.500                     | 8.000      | 8.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 0.000                      | 4.000      | 4.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |

**Visual Inspection (Checklist if OK)**

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

**Standard Reference**

| Description                              | Serial Number | Certificate Number | Calibration Date |
|------------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 56070038      | MAL 26031230       | 06-03-2026       |
| FLUKE PRESURE MODULE 700P08              | 14070813      | MAL 26031235       | 03-03-2026       |

**Calibration Method**

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 03-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Ivan Masari Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person