

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0623-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LCA62CT005	Range	0 ~ 150
Instrument Description	LP HEATER 2 OUTLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	TM	Max. Deviation	1.7 °C (JIS)
Serial Number	-	Cal. Date	18-05-2024
Instrument Location	TURBINE 2ND FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 25.2 °C
Humidity 67 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.100	40.000	-0.100	Pass					
60	60.010	60.600	0.590	Pass					
90	90.000	91.000	1.000	Pass					
120	120.000	121.400	1.400	Pass					
150	150.000	151.200	1.200	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 19-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taqib Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

