

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0389-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.:	60LCA70CF005	Range:	0 ~ 1300
Instrument Description:	DEAERATOR INLET WATER FLOW 1	Unit:	mbar
Manufacture:	YOKOGAWA	Out. Signal:	4 - 20 mA
Model:	EJX110A	Max. Error:	0.5 %
Serial Number:	91V703352	Cal. Date:	29-05-2024
Instrument Location:	TURBINE 3RD FLOOR		

Environment Condition

Temperature: 30.9 °C
Humidity: 66 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0	4.000	4.000	0.000	0.000	Pass						
325	8.000	8.000	0.000	0.000	Pass						
650	12.000	11.998	-0.002	-0.013	Pass						
975	16.000	16.000	0.000	0.000	Pass						
1300	20.000	20.000	0.000	0.000	Pass						
1300	20.000	20.000	0.000	0.000	Pass						
975	16.000	16.000	0.000	0.000	Pass						
650	12.000	11.998	-0.002	-0.013	Pass						
325	8.000	7.998	-0.002	-0.012	Pass						
0	4.000	3.999	-0.001	-0.006	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fityan
INDONESIA

Calibrated by,



Handi Suryawinata

This certificate comprise of 1 page
Date of issue, 30-05-2024

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

