

CERTIFICATE OF CALIBRATION  
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0483-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60LCA70CF005  
Instrument Description DEAERATOR INLET WATER FLOW 1  
Manufacture YOKOGAWA  
Model / Serial Number EJX110A / 91V703352  
Instrument Location TURBINE 3RD FLOOR

Range 0 ~ 1300  
Unit mbar  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 06-06-2026

## Environment Condition

Temperature 31 °C Humidity 74 % RH

## Calibration Result

| Data Reading (Transmitter) |            |            |           |       |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|-------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |       |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [mbar]                     | [mA]       | [mA]       |           | [%]   |        | [mbar]  | [mA]       | [mA]       |           | [%]   |        |
| 0.000                      | 4.000      | 4.000      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 325.000                    | 8.000      | 8.000      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 650.000                    | 12.000     | 12.000     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 975.000                    | 16.000     | 16.000     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 1300.000                   | 20.000     | 20.000     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 975.000                    | 16.000     | 16.000     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 650.000                    | 12.000     | 12.000     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 325.000                    | 8.000      | 8.000      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 0.000                      | 4.000      | 4.000      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |

## Visual Inspection (Checklist if OK)

Leak Check ☒Tightness Check ☒Corrosion Check ☒Accessories Check ☒Power Supply ☒

## Standard Reference

| Description                              | Serial Number | Certificate Number   | Calibration Date |
|------------------------------------------|---------------|----------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 2448033       | 4482/25/EX/10/2025   | 26-09-2025       |
| FLUKE PRESURE MODULE 750PD6              | 6094437       | 02170/GQI-Sert/03/26 | 09-03-2026       |

## Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 10-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

HERVITAMA

INDONESIA

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia  
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person