

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0391-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LCA70CP005	Range	-1 ~ 30
Instrument Description	DEAERATOR INLET WATER PRESSURE	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4-20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V703382	Cal. Date	09-05-2024
Instrument Location	TURBINE 4TH FLOOR		

### Environment Condition

Temperature 31.5 °C  
Humidity 66 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.800	4.103	4.096	-0.007	-0.044	Pass						
6.750	8.000	7.990	-0.010	-0.062	Pass						
14.500	12.000	11.989	-0.011	-0.069	Pass						
22.256	16.000	15.993	-0.007	-0.044	Pass						
30.006	20.000	19.991	-0.009	-0.056	Pass						
30.006	20.000	19.991	-0.009	-0.056	Pass						
22.256	16.000	16.014	0.014	0.087	Pass						
14.500	12.000	11.988	-0.012	-0.075	Pass						
6.750	8.000	7.991	-0.009	-0.056	Pass						
-0.800	4.103	4.093	-0.010	-0.062	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page

Date of issue, 10-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

