

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0179-24-HI-CAL-101

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.: 60LCC10CL015  
Instrument Description: LP HEATER 1 LEVEL 3  
Manufacture: TOKYO KEISO  
Model: FST 4512  
Serial Number: L19-10464-1.3  
Instrument Location: TURBINE 2ND FLOOR

Range: NWL-750 ~ NWL+350  
Unit: mm  
Out. Signal: 4 - 20 mA  
Max. Error: 0.5 %  
Cal. Date: 27-05-2024

### Environment Condition

Temperature: 33 °C  
Humidity: 44 % RH

### Calibration Result

Data Reading (Transmitter)															
As Found					As Left										
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-750	-750	-749	4.000	4.010	0.010	0.063	Pass								
-475	-475	-478	8.000	7.960	-0.040	-0.250	Pass								
-200	-200	-199	12.000	12.010	0.010	0.063	Pass								
75	75	75	16.000	15.980	-0.020	-0.125	Pass								
350	350	350	20.000	19.990	-0.010	-0.063	Pass								

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
Date of issue, 28-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Hafidyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

