

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0180-24-HI-CAL-10I

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LCC20CL005	Range	NWL-220 ~ NWL+650
Instrument Description	LP HEATER 2 LEVEL 1	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model	FST 4412	Max. Error	0.5 %
Serial Number	L19-10464-2-1	Cal. Date	25-05-2024
Instrument Location	TURBINE 2ND FLOOR		

### Environment Condition

Temperature 33 °C  
Humidity 43 % RH

### Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-220.0	-220.0	-219	4.000	4.000	0.000	0.000	Pass								
-2.5	-2.5	-4	8.000	7.960	-0.040	-0.250	Pass								
215.0	215.0	217	12.000	12.010	0.010	0.063	Pass								
432.0	432.0	432	16.000	15.970	-0.030	-0.188	Pass								
650.0	650.0	653	20.000	20.030	0.030	0.188	Pass								

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
Date of issue, 26-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Fauzan M. Ariyan

Calibrated by,

R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

*\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

*This certificate is valid if it has approved and signed by authorized person*

