

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 1124-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60LCC20CL005	Range	-220 ~ 650
Instrument Description	LP HEATER 2 LEVEL 1	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model / Serial Number	FST 4412 / L19-10464-2-1	Max. Error	0.5%
Instrument Location	TURBINE 2ND FLOOR	Cal. Date	26-05-2026

Environment Condition

Temperature 30 °C Humidity 81 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-220	-219	-214	-	5.000	0.575	Fail	-220	-184	-182	4.690	2.000	0.230	Pass
-25	-29	-33	-	-4.000	-0.460	Pass	-25	19	22	8.450	3.000	0.345	Pass
215	194	197	-	3.000	0.345	Pass	215	222	225	12.180	3.000	0.345	Pass
432.5	409	405	-	-4.000	-0.460	Pass	432.5	461	464	16.570	3.000	0.345	Pass
660	626	621	-	-5.000	-0.575	Fail	660	652	656	20.110	4.000	0.460	Pass

Visual Inspection (Checklist if OK)

Leak Check	☒	Tightness Check	☒	Corrosion Check	☒
Accessories Check	☒	Power Supply	☒		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 02-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Authorized Signature,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person