

CERTIFICATE OF CALIBRATION  
LEVEL TRANSMITTER

Certificate No. : 1125-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

|                        |                          |             |            |
|------------------------|--------------------------|-------------|------------|
| KKS No.                | 60LCC20CL010             | Range       | -220 ~ 650 |
| Instrument Description | LP HEATER 2 LEVEL 2      | Unit        | mm         |
| Manufacture            | TOKYO KEISO              | Out. Signal | 4 - 20 mA  |
| Model / Serial Number  | FST 4000 / L19-10464-2-2 | Max. Error  | 0.5%       |
| Instrument Location    | TURBINE 2ND FLOOR        | Cal. Date   | 26-05-2026 |

## Environment Condition

Temperature 30 °C Humidity 81 % RH

## Calibration Result

| Data Reading (Transmitter) |            |            |            |           |        |        |         |            |            |            |           |        |        |
|----------------------------|------------|------------|------------|-----------|--------|--------|---------|------------|------------|------------|-----------|--------|--------|
| As Found                   |            |            |            |           |        |        | As Left |            |            |            |           |        |        |
| Input                      | Std Output | Output UUT | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Output UUT | Deviation | Error  | Result |
| [mm]                       | [mm]       | [mm]       | [mA]       |           | [%]    |        | [mm]    | [mm]       | [mm]       | [mA]       |           | [%]    |        |
| -220                       | -178       | -184       | -          | -6.000    | -0.690 | Fail   | -220    | -208       | -207       | 4.230      | 1.000     | 0.115  | Pass   |
| -25                        | -21        | -13        | -          | 8.000     | 0.920  | Fail   | -25     | 16         | 17         | 8.350      | 1.000     | 0.115  | Pass   |
| 215                        | 220        | 217        | -          | -3.000    | -0.345 | Pass   | 215     | 208        | 211        | 11.920     | 3.000     | 0.345  | Pass   |
| 432.5                      | 450        | 446        | -          | -4.000    | -0.460 | Pass   | 432.5   | 433        | 436        | 16.040     | 3.000     | 0.345  | Pass   |
| 660                        | 639        | 639        | -          | 0.000     | 0.000  | Pass   | 660     | 651        | 650        | 20.000     | -1.000    | -0.115 | Pass   |

## Visual Inspection (Checklist if OK)

|                   |                                     |                 |                                     |                 |                                     |
|-------------------|-------------------------------------|-----------------|-------------------------------------|-----------------|-------------------------------------|
| Leak Check        | <input checked="" type="checkbox"/> | Tightness Check | <input checked="" type="checkbox"/> | Corrosion Check | <input checked="" type="checkbox"/> |
| Accessories Check | <input checked="" type="checkbox"/> | Power Supply    | <input checked="" type="checkbox"/> |                 |                                     |

## Standard Reference

| Description                  | Serial Number  | Certificate Number   | Calibration Date |
|------------------------------|----------------|----------------------|------------------|
| DIGITAL LASER DISTANCE METER | 18H114632      | 02169/GQI-Sert/03/26 | 09-03-2026       |
| STEEL TAPE MEASURE           | 001/L1/HI/2026 | 01231/GQI-Sert/02/26 | 09-02-2026       |

## Calibration Method

0005/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages  
Date of issue, 02-06-2026

Customer Signature,

Ayron Humardani Putradhi

Approved Signatory,

  
INDONESIA  
Iyan Hasan Ashari

Calibrated by,

  
Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

