

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0182-24-HI-CAL-101

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60LCC20CL015 Range NWL-220 ~ NWL+650
 Instrument Description LP HEATER 2 LEVEL 3 Unit mm
 Manufacture - Out. Signal 4 - 20 mA
 Model - Max. Error 0.5 %
 Serial Number - Cal. Date 25-05-2024
 Instrument Location TURBINE 2ND FLOOR

Environment Condition

Temperature 33 °C
 Humidity 44 % RH

Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-220	-220	-219	4.000	4.000	0.000	0.000	Pass								
-2.5	-2.5	-4	8.000	7.960	-0.040	-0.250	Pass								
215	215	217	12.000	12.010	0.010	0.063	Pass								
432	432	432	16.000	15.970	-0.030	-0.188	Pass								
650	650	653	20.000	20.030	0.030	0.188	Pass								

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Indriyana

Calibrated by,



R. Hery Setyo Ulomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person