

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 1126-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LCC20CL015 Range -220 ~ 650
Instrument Description LP HEATER 2 LEVEL 3 Unit mm
Manufacture TOKYO KEISO Out. Signal 4 - 20 mA
Model / Serial Number FST 4000 / L19-10464-2-3 Max. Error 0.5%
Instrument Location TURBINE 2ND FLOOR Cal. Date 26-05-2026

Environment Condition

Temperature 30 °C Humidity 81 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-220	-192	-186	-	6.000	0.690	Fail	-220	-206	-210	4.184	-4.000	-0.460	Pass
-25	12	23	-	11.000	1.264	Fail	-25	15	18	8.377	3.000	0.345	Pass
215	232	248	-	16.000	1.839	Fail	215	219	221	12.110	2.000	0.230	Pass
432.5	422	439	-	17.000	1.954	Fail	432.5	416	420	15.770	4.000	0.460	Pass
660	624	645	-	21.000	2.414	Fail	660	652	651	20.018	-1.000	-0.115	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 02-06-2026

Customer Signature,

Ayron Humardani Putradhi

Approved Signatory,

HERVITAMA
INDONESIA
Ivan Hasan Asadri

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

