

## CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0183-24-HI-CAL-101

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LCC30CL005	Range	CL-850 ~ CL ± 0
Instrument Description	LP HEATER 3 LEVEL 1	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model	FST 4412	Max. Error	0.5 %
Serial Number	L19-10464-3-1	Cal. Date	25-05-2024
Instrument Location	TURBINE 2ND FLOOR		

### Environment Condition

Temperature 33 °C  
Humidity 43 % RH

### Calibration Result

Data Reading (Transmitter)																
As Found								As Left								
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]		
-825.0	-825.0	-824	4.000	4.020	0.020	0.125	Pass									
-612.5	-612.5	-612	8.000	8.010	0.010	0.063	Pass									
-400.0	-400.0	-394	12.000	12.050	0.050	0.313	Pass									
-187.5	-187.5	-189	16.000	15.960	-0.040	-0.250	Pass									
25.0	25.0	24	20.000	19.980	-0.020	-0.125	Pass									

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

### Calibration Method

0009/SOP\_BJS/2023  
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page  
Date of issue, 27-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

