

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0186-24-HI-CAL-101

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LCC40CL005	Range	NWL-250 ~ NWL+650
Instrument Description	LP HEATER 4 LEVEL 1	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model	FST 4412	Max. Error	0.5 %
Serial Number	L19-10464-4-1	Cal. Date	25-05-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature 33 °C
Humidity 42 % RH

Calibration Result

As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-250	-250	-247	4.000	4.020	0.020	0.125	Pass								
-25	-25	-24	8.000	8.010	0.010	0.063	Pass								
200	200	201	12.000	12.000	0.000	0.000	Pass								
425	425	432	16.000	16.000	0.000	0.000	Pass								
650	650	650	20.000	20.040	0.040	0.250	Pass								

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

