

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0187-24-HI-CAL-101

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60LCC40CL010 Range: NWL-250 ~ NWL+650
Instrument Description: LP HEATER 4 LEVEL 2 Unit: mm
Manufacture: TOKYO KEISO Out. Signal: 4 - 20 mA
Model: FST 4412 Max. Error: 0.5 %
Serial Number: L19-10464-4-2 Cal. Date: 25-05-2024
Instrument Location: TURBINE 2ND FLOOR

Environment Condition

Temperature: 33 °C
Humidity: 42 % RH

Calibration Result

As Found									As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]		
-250	-250	-251	4.000	3.980	-0.020	-0.125	Pass									
-25	-25	-24	8.000	8.010	0.010	0.063	Pass									
200	200	201	12.000	12.010	0.010	0.063	Pass									
425	425	426	16.000	16.000	0.000	0.000	Pass									
650	650	652	20.000	20.030	0.030	0.188	Pass									

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Heru Setyo Utomo

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

