

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 1131-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60LCC40CL010

Instrument Description

LP HEATER 4 LEVEL 2

Manufacture

TOKYO KEISO

Model / Serial Number

FST 4412 / L19-10464-4-2

Instrument Location

TURBINE 2ND FLOOR

Range

-250 ~ 650

Unit

mm

Out. Signal

4 - 20 mA

Max. Error

0.5%

Cal. Date

03-06-2026

Environment Condition

Temperature

30 °C

Humidity

84 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-220	-250	-241	4.158	9.000	1.000	Fail	-220	-242	-246	4.071	-4.000	-0.444	Pass
-25	17	4	8.466	-13.000	-1.444	Fail	-25	16	14	8.693	-2.000	-0.222	Pass
200	266	256	12.897	-241.000	-26.778	Fail	200	260	258	13.031	-2.000	-0.222	Pass
425	461	451	16.325	-10.000	-1.111	Fail	425	468	467	16.747	-1.000	-0.111	Pass
650	650	650	19.824	0.000	0.000	Pass	650	650	650	20.000	0.000	0.000	Pass

Visual Inspection (Checklist if OK)

Leak Check

☒

Tightness Check

☒

Corrosion Check

☒

Accessories Check

☒

Power Supply

☒

Standard Reference

Description

DIGITAL LASER DISTANCE METER

STEEL TAPE MEASURE

Serial Number

18H114632

001/L1/HI/2026

Certificate Number

02169/GQI-Sert/03/26

01231/GQI-Sert/02/26

Calibration Date

09-03-2026

09-02-2026

Calibration Method

0005/SOP_BJS/2025

Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages

Date of issue, 08-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

HERVITAMA
Approved Signatory,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person