

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 1132-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60LCC40CL015	Range	-250 ~ 650
Instrument Description	LP HEATER 4 LEVEL 3	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model / Serial Number	FST 4412 / L19-10464-4-3	Max. Error	0.5%
Instrument Location	TURBINE 2ND FLOOR	Cal. Date	03-06-2026

Environment Condition

Temperature 30 °C Humidity 84 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-220	-228	-238	4.211	-10.000	-1.111	Fail	-220	-232	-232	4.320	0.000	0.000	Pass
-25	17	5	8.484	-12.000	-1.333	Fail	-25	-25	-24	8.018	1.000	0.111	Pass
200	223	213	12.141	-10.000	-1.111	Fail	200	198	200	12.000	2.000	0.222	Pass
425	434	425	15.868	-9.000	-1.000	Fail	425	411	410	15.733	-1.000	-0.111	Pass
650	650	640	19.648	-10.000	-1.111	Fail	650	650	650	20.000	0.000	0.000	Pass

Visual Inspection (Checklist if OK)

Leak Check	☒	Tightness Check	☒	Corrosion Check	☒
Accessories Check	☒	Power Supply	☒		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 08-06-2026

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person