

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0486-26-HI-CAL-10

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LCE20CP005
Instrument Description LP TURBINE CASING SPRAY PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703390
Instrument Location TURBINE 3RD FLOOR

Range -1 ~ 60
Unit bar g
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 16-06-2026

Environment Condition

Temperature 32.4 °C Humidity 50 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.800	4.052	4.052	0.000	0.000	Pass						
14.251	8.000	8.002	0.002	0.013	Pass						
29.503	12.000	12.002	0.002	0.013	Pass						
44.754	16.001	16.001	0.000	0.000	Pass						
60.005	20.001	20.004	0.003	0.019	Pass						
44.754	16.001	16.003	0.002	0.013	Pass						
29.496	11.998	12.003	0.005	0.031	Pass						
14.251	8.000	8.001	0.001	0.006	Pass						
-0.800	4.052	4.052	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESURE MODULE 700P08	14070813	MAL 26031235	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 17-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Appr. **HERVITAMA**INDONESIA
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person