

REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1257-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60LCH20AA220	Sensitivity	0.3 %
Instrument Description	HP HEATER 7A LEVEL CONTROL VALVE	Damping Time	0.4 s
Manufacture	FISHER	Actuator Action	ATO
Model	AAD657	Inspection Date	18-05-2024
Serial Number	J231089		
Instrument Location	TURBINE 3RD FLOOR		

Environment Condition

Temperature 30 °C Humidity 42 % RH

Traveling Time

Open to Close 03.96 s Close to Open 02.51 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]
0	0.1	3.960	0.20	0.00
25	24.9	7.950	25.00	12.75
50	49.9	11.910	49.95	25.50
75	74.7	15.890	74.81	38.52
100	100.0	19.920	100.10	51.00

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]
0	-0.1	4.010	0.20	0.00
25	25.0	7.980	24.90	12.75
50	49.7	11.930	49.50	25.50
75	74.9	15.900	74.80	38.25
100	100.0	19.990	98.60	51.00

Visual Inspection

Leak Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Tightness Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Corrosion Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Accessories Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Air Regulator Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK					

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022
AMS Trex Device Communicator	230200023794	-	16-05-2024

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 19-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

