

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0632-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60LCH30CT005	Range	0 ~ 250
Instrument Description	HP HEATER 6A DRAIN TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	2.5 °C
Serial Number	5346967	Cal. Date	19-05-2024
Instrument Location	TURBINE 3RD FLOOR	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 26.2 °C  
Humidity 60 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.010	40.300	0.290	Pass					
62.5	62.500	63.100	0.600	Pass					
125.0	125.000	126.400	1.400	Pass					
187.5	187.530	189.200	1.670	Pass					
250.0	250.030	252.200	2.170	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
Date of issue, 20-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. INDANESTIYAN

Calibrated by,



Khahib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

