

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0633-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LCH31CT005	Range	0 ~ 250
Instrument Description	HP HEATER 6B DRAIN TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	2.5 °C
Serial Number	5346968	Cal. Date	19-05-2024
Instrument Location	TURBINE 3RD FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 25.8 °C
Humidity 63 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40.0	40.000	40.300	0.300	Pass					
62.5	62.500	63.100	0.600	Pass					
125.0	125.010	126.400	1.390	Pass					
187.5	187.490	189.300	1.810	Pass					
250.0	250.010	252.200	2.190	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 20-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,
HERVITAMA



M. Idris Sidiyan

Calibrated by,



Khajib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person

