

REPORT OF INSPECTION CONTROL VALVE Certificate No. : 1267-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60LCJ10AA220 Sensitivity 0.5 %
 Instrument Description LP HEATER 4 LEVEL CONTROL VALVE Damping Time 0.5 s
 Manufacture FISHER Actuator Action ATO
 Model ET-657 Inspection Date 10-05-2024
 Serial Number J231097
 Instrument Location TURBINE 2ND FLOOR

Environment Condition

Temperature 30.1 °C Humidity 48 % RH Traveling Time
 Open to Close 2.20 s Close to Open 7.40 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]
0	-0.2	3.960	0.0	0
25	24.8	7.960	24.9	12.75
50	49.9	11.980	50.0	23.50
75	74.8	15.960	74.9	38.25
100	9.8	19.960	99.9	31

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
 Corrosion Condition OK Not OK Accessories Check OK Not OK
 Air Regulator Check OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023
Hartcomm 475	11113878		-
FIK-87-V MULTIMETER	45910296	S. 22 008 273	13-07-2022

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 11-05-2024

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

M. Fauzi Nur Fitriyan

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

