

**CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER**

Certificate No. : 1133-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LCJ10CL005
Instrument Description LP HEATER DRAIN TANK LEVEL 1
Manufacture TOKYO KEISO
Model / Serial Number FST 4612 / L19-10464-5-1
Instrument Location TURBINE 2ND FLOOR

Range -1050 ~ 500
Unit mm
Out. Signal 4 - 20 mA
Max. Error 0.5%
Cal. Date 25-05-2026

Environment Condition

Temperature 30 °C Humidity 78 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-1050.0	-1063	-1068	3.900	-5.000	-0.323	Pass	-1050	-1055	-1051	3.990	4.000	0.258	Pass
-662.5	-673	-696	7.654	-23.000	-1.484	Fail	-662.5	-660	-665	7.974	-5.000	-0.323	Pass
-275.0	-274	-306	11.680	-32.000	-2.065	Fail	-275	-263	-270	12.052	-7.000	-0.452	Pass
-112.5	125	68	15.540	-57.000	-3.677	Fail	112.5	125	120	16.077	-5.000	-0.323	Pass
500.0	507	458	19.566	-49.000	-3.161	Fail	500	513	507	20.072	-6.000	-0.387	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Laser Distance Meter	-	S. 24 013 432	17-09-2024
DOCUMENTING PROCESS	3611011	MAL 26031229	06-03-2026
CALIBRATOR FLUKE 754			

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 28-05-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

HERVITAMA
INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

