

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0190-24-HI-CAL-101

Customer Information

Company Name PT. Bumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60LCJ10CL010	Range	NWL-1050 ~ NWL+500
Instrument Description	LP HEATER DRAIN TANK LEVEL 12	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model	FST 4612	Max. Error	0.5 %
Serial Number	L19-10464-5-2	Cal. Date	27-05-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature 33 °C
 Humidity 43 % RH

Calibration Result

Data Reading (Transmitter)															
As Found					As Left										
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-1050	-1050	-1046	4.000	4.050	0.050	0.313	Pass								
-662.5	-662.5	-663	8.000	7.980	-0.020	-0.125	Pass								
-275	-275	-275	12.000	12.000	0.000	0.000	Pass								
112.5	112.5	112	16.000	15.990	-0.010	-0.063	Pass								
500	500	499	20.000	19.980	-0.020	-0.125	Pass								

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
True RMS Multimeter Constant	160403266	SCL/23/3123/EY	14-11-2023

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 28-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taqwa Nur Hafidhan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person