

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 1134-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60LCJ10CL010
 Instrument Description LP HEATER DRAIN TANK LEVEL 12
 Manufacture TOKYO KEISO
 Model / Serial Number FST 4612 / L19-10464-5-2
 Instrument Location TURBINE 2ND FLOOR

Range -1050 ~ 500
 Unit mm
 Out. Signal 4 - 20 mA
 Max. Error 0.5%
 Cal. Date 25-05-2026

Environment Condition

Temperature 30 °C Humidity 79 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-1050	-1063	-1058	3.900	5.000	0.323	Fail	-1050	-1058	-1054	3.959	4.000	0.258	Pass
-622.5	-673	-685	7.767	-12.000	-0.774	Fail	-622.5	-661	-667	7.954	-6.000	-0.387	Pass
-275	-271	-283	11.917	-12.000	-0.774	Fail	-275	-272	-266	12.093	6.000	0.387	Pass
112.5	125	116	16.036	-9.000	-0.581	Fail	112.5	127	123	16.108	-4.000	-0.258	Pass
500	507	488	19.876	-19.000	-1.226	Fail	500	501	504	20.041	3.000	0.194	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
 Accessories Check ☒ Power Supply ☒

Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

Calibration Method

001 / Service-HI / 2019
 Standard Operating Procedure of Pressure Transmitter Calibration

This certificate comprises 2 pages
 Date of issue, 26-05-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

HERVITAMA

 INDONESIA

Ivan Hasan Asfari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person