

## REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1269-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No.	60LCJ30AA220	Sensitivity	0.9 %
Instrument Description	LP HEATER 2 LEVEL CONTROL VALVE	Damping Time	0.5 s
Manufacture	FISHER	Actuator Action	ATC
Model	ET657	Inspection Date	18-05-2024
Serial Number	J231099		
Instrument Location	TURBINE 2ND FLOOR		

### Environment Condition

Temperature 31 °C Humidity 42 % RH

### Traveling Time

Open to Close 03.19 s Close to Open 05.49 s

### Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]
0	0.00	4.000	0.3	0.00
25	25.10	8.020	25.3	12.75
50	50.06	12.010	50.2	25.50
75	75.00	16.000	75.2	38.25
100	100.00	20.000	100.2	51.00

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]
0	0.00	4.000	0.0	0.00
25	25.00	8.000	25.0	12.75
50	50.06	12.010	50.1	25.50
75	75.00	16.000	75.2	28.25
100	100.00	20.000	100.0	51.00

### Visual Inspection

Leak Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Tightness Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Corrosion Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Accessories Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Air Regulator Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK					

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022
AMS Trex Device Communicator	230200023794	-	16-05-2024

### Inspection Method


0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Indro Nugroho

Calibrated by,



Daday Daryatun

This certificate comprise of 1 page  
Date of issue, 19-05-2024

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

