

## REPORT OF INSPECTION

### ON-OFF VALVE

Certificate No. : 1270-24-HI-CAL-10J

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

#### Instrument Information

KKS No. 60LCJ30AA905 Damping Time 0.09 s  
Instrument Description LP HEATER 2 CASCADE DRAIN VENT VALVE Inspection Date 16-05-2024  
Manufacture NAKAKITA  
Model NS650  
Serial Number 19CY0748  
Instrument Location TURBINE 2ND FLOOR

#### Environment Condition

Temperature 30 °C  
Humidity 44 % RH  
Traveling Time  
Open to Close 00.23 s  
Close to Open 00.19 s

#### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

#### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK

#### Remark

#### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

#### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 17-05-2024

Customer Signature,

Ayron Humardani Putradhi

Approved Signatory,

M. Tadiq Nur Fitriyan  
INDONESIA

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

