

## REPORT OF INSPECTION MOTORIZED OF VALVE Certificate No. : 0922-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60LCJ61AA210 **Power Supply**: 380 VAC  
 Instrument Description: LP HTR DRAIN TANK OTL CONDR COLLECTION **Stroke**: 400 mm  
 VALVE  
 Manufacture: ROTORK  
 Model: 1Q19-F14 **Inspection Date**: 16-05-2024  
 Serial Number: NT38302901  
 Instrument Location: TURBINE 1ST FLOOR

### Environment Condition

Temperature: 31 °C **Traveling Time**  
 Humidity: 44 % RH **Open to Close**: 68.37 s  
**Close to Open**: 68.64 s

### Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	-
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK **Tightness Check**:  OK  Not OK  
 Corrosion Condition:  OK  Not OK **Accessories Check**:  OK  Not OK  
 Gearbox Condition:  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 17-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Tahir Nur Hidayat

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

