

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0487-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60MAA10CP005	Range	0.55 ~ 300.55
Instrument Description	HP TURBINE 1ST STAGE PRESSURE 1	Unit	bar g
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX440A / 91V703037	Max. Error	0.5 %
Instrument Location	TURBINE 2ND FLOOR	Cal. Date	16-06-2026

Environment Condition

Temperature 32. °C Humidity 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
0.550	4.000	4.000	0.000	0.000	Pass						
75.570	8.001	8.001	0.000	0.000	Pass						
150.580	12.001	12.005	0.004	0.025	Pass						
225.530	15.998	16.003	0.005	0.031	Pass						
300.540	19.999	19.997	-0.002	-0.013	Pass						
225.530	15.998	16.001	0.003	0.019	Pass						
150.510	11.997	12.001	0.004	0.025	Pass						
75.570	8.001	8.004	0.003	0.019	Pass						
0.550	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒	Tightness Check ☒	Corrosion Check ☒
Accessories Check ☒	Power Supply ☒	

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 17-06-2026

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA
Approved Signature



INDONESIA
Ivan Hasan Ashari

Calibrated by,



Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person