

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER Certificate No. : 0393-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAA10CP010	Range	0.55 ~ 300.55
Instrument Description	HP TURBINE 1ST STAGE PRESSURE 2	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V703038	Cal. Date	16-05-2024
Instrument Location	TURBINE 2ND FLOOR		

Environment Condition

Temperature: 30.2 °C
 Humidity: 65 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.55	4.000	3.992	-0.008	-0.050	Pass						
75.57	8.001	7.990	-0.011	-0.069	Pass						
150.58	12.002	11.994	-0.008	-0.050	Pass						
225.53	16.002	15.995	-0.007	-0.044	Pass						
300.54	19.999	19.993	-0.006	-0.038	Pass						
300.54	19.999	19.993	-0.006	-0.038	Pass						
225.53	16.002	15.996	-0.006	-0.037	Pass						
150.58	12.002	11.996	-0.006	-0.038	Pass						
75.57	8.001	7.994	-0.007	-0.044	Pass						
0.55	4.000	3.987	-0.013	-0.081	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 17-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved by,



M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

