

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0898-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60MAA10CT010

MAIN STOP VALVE A INNER METAL TEMPERATURE

YAMARI

- / -

Turbine 3rd Floor

Range

Unit

Out. Signal

Max. Deviation

Cal. Date

Temp. Element

0 ~ 700

°C

4-20 mA

7 °C

30-06-2026

Thermocouple Type K

Environment Condition

Temperature

30.1 °C

Humidity

51 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-0.400	-0.400	Pass					
175	175.000	174.400	-0.600	Pass					
350	350.000	349.900	-0.100	Pass					
525	525.000	525.000	0.000	Pass					
700	700.000	700.200	0.200	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

Temperature Calibrator Fluke 725

2815000

2256/25/KAL/06/2025

23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 01-07-2026

Customer Signature,

Ayron Humardani Pultradihi

Approved Signatory,

Hanjusan Aslari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

