

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0906-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAA10CT050
Instrument Description HP TURBINE LOWER INNER METAL EXHAUST TEMPERATURE
Manufacture YAMARI
Model / Serial Number - / -
Instrument Location Turbine 3rd Floor

Range 0 ~ 700
Unit °C
Out. Signal 4-20 mA
Max. Deviation 7 °C
Cal. Date 30-06-2026
Temp. Element Thermocouple Type K

Environment Condition

Temperature 30.1 °C Humidity 51 % RH

Calibration Result

Data Reading					Data Reading				
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-0.100	-0.100	Pass					
175	175.000	174.600	-0.400	Pass					
350	350.000	349.600	-0.400	Pass					
525	525.000	524.700	-0.300	Pass					
700	700.000	699.800	-0.200	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description Serial Number Certificate Number Calibration Date
Temperature Calibrator Fluke 725 2815000 2256/25/KAL/06/2025 23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 01-07-2026

Customer Signature,

Approved Signatory,

Calibrated by,



Ayron Humardani Putradhi


HERVITAMA
INDONESIA

Ivan Hasan Ashari



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

