

## REPORT OF INSPECTION MOTORIZED OF VALVE Certificate No. : 0927-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60MAA12AA810  
 Instrument Description: HP TURBINE OUTER CASING DRAIN VALVE  
 Manufacture: ROTORK  
 Model: 1Q10-F10 A  
 Serial Number: 29668401  
 Instrument Location: TURBINE 2ND FLOOR

Power Supply: 380 VAC  
 Stroke: 20 mm  
 Inspection Date: 16-05-2024

### Environment Condition

Temperature: 30 °C  
 Humidity: 44 % RH

Traveling Time  
 Open to Close: 14.56 s  
 Close to Open: 15.67 s

### Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK  
 Corrosion Condition:  OK  Not OK  
 Gearbox Condition:  OK  Not OK

Tightness Check:  OK  Not OK  
 Accessories Check:  OK  Not OK

Remark

### Test Equipment

Description  
 FIK-87-V MULTIMETER  
 STOPWATCH CASIO

Serial Number  
 16230349  
 J011Q03

Certificate Number  
 S. 22 008 274  
 S. 23 004 599

Calibration Date  
 08-07-2022  
 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 17-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,

Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person