

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0910-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60MAA20CT010

Instrument Description

MAIN STOP VALVE B INNER METAL TEMPERATURE

Manufacture

YAMARI

Model / Serial Number

PH / PTU

Instrument Location

TURBINE 3RD FLOOR

Range

0 ~ 700

Unit

°C

Out. Signal

4 - 20 mA

Max. Deviation

7 °C

Cal. Date

30-06-2026

Temp. Element

Thermocouple Type E

Environment Condition

Temperature

25.6 °C

Humidity

64 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	0.100	0.100	Pass					
175	175.000	174.600	-0.400	Pass					
350	350.000	349.700	-0.300	Pass					
525	525.000	524.900	-0.100	Pass					
700	700.000	700.100	0.100	Pass					

Visual Inspection (Checklist if OK)

Leak Check

☐

Tightness Check

☒

Corrosion Check

☒

Accessories Check

☒

Power Supply

☐

Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

Temperature Calibrator Fluke 725

2815000

2256/25/KAL/06/2025

23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 01-07-2026

Customer Signature,

Approved Signatory,

Calibrated by,

Ayron Humardani Putradhi

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Khabib Mundzini Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ljin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person