

CERTIFICATE OF CALIBRATION

TEMPERATURE SENSOR

Certificate No. : 0911-26-HI-CAL-10

Customer Information

Company Name

PT. Bumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60MAA20CT015

Instrument Description

MAIN STOP VALVE B OUTER METAL TEMPERATURE

Manufacture

YAMARI

Model / Serial Number

- / -

Instrument Location

TURBINE 3RD FLOOR

Range

0 ~ 700

Unit

°C

Out. Signal

4-20 mA

Max. Deviation

7 °C

Cal. Date

30-06-2026

Temp. Element

Thermocouple Type K

Environment Condition

Temperature

30.1 °C

Humidity

51 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-0.400	-0.400	Pass					
175	175.000	174.600	-0.400	Pass					
350	350.000	349.800	-0.200	Pass					
525	525.000	525.000	0.000	Pass					
700	700.000	700.100	0.100	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

Temperature Calibrator Fluke 725

2815000

2256/25/KAL/06/2025

23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 01-07-2026

Customer Signature,

Approved Signatory,

Calibrated by,

Ayron Humardani Putradhi

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

