

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0490-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAB10CP005
Instrument Description IP TURBINE REHEAT BOWL PRESSURE 1
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703391
Instrument Location TURBINE 2ND FLOOR

Range 0.47 ~ 70.46
Unit bar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 29-05-2026

Environment Condition

Temperature 30.8 °C Humidity 65 % RH

Calibration Result

Data Reading (Transmitter)										
As Found						As Left				
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]
0.480	4.002	4.011	0.009	0.056	Pass					
18.000	8.007	8.008	0.001	0.006	Pass					
35.440	11.994	12.000	0.006	0.038	Pass					
52.950	15.997	16.005	0.008	0.050	Pass					
70.460	20.000	20.004	0.004	0.025	Pass					
52.950	15.997	16.001	0.004	0.025	Pass					
35.440	11.994	12.000	0.006	0.038	Pass					
18.000	8.007	8.010	0.003	0.019	Pass					
0.480	4.002	4.000	-0.002	-0.013	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 03-06-2026

Customer Signature,

Ayrlton Humardani Putradhi

HERVITAMA Indonesia,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person