

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0492-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAB10CP015
Instrument Description IP TURBINE TURBINE SIDE EXHAUST STEAM PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V703393
Instrument Location TURBINE 3RD FLOOR

Range -0.765 ~ 15.235
Unit bar g
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 16-06-2026

Environment Condition

Temperature 32.4 °C Humidity 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar g]	[mA]	[mA]		[%]		[bar g]	[mA]	[mA]		[%]	
-0.765	4.000	4.001	0.001	0.006	Pass						
3.235	8.000	8.002	0.002	0.013	Pass						
7.234	11.999	12.002	0.003	0.019	Pass						
11.235	16.000	16.004	0.004	0.025	Pass						
15.235	20.000	20.004	0.004	0.025	Pass						
11.235	16.000	16.005	0.005	0.031	Pass						
7.235	12.000	12.009	0.009	0.056	Pass						
3.325	8.000	8.005	0.005	0.031	Pass						
-0.765	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 17-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Authorized Signatory,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person