

**CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR**

Certificate No. : 0914-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAB10CT005
Instrument Description IP TURBINE REHEAT BOWL UPPER INNER METAL TEMPERATURE
Manufacture YAMARI
Model / Serial Number - / -
Instrument Location TURBINE 3RD FLOOR

Range 0 ~ 700
Unit °C
Out. Signal 4 - 20 mA
Max. Deviation 7 °C
Cal. Date 11-06-2026
Temp. Element Thermocouple Type E

Environment Condition

Temperature 25.7 °C Humidity 73 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-1.100	-0.0011	Pass					
175	175.000	174.000	-0.001	Pass					
350	350.000	349.000	-0.001	Pass					
525	525.000	524.100	-0.900	Pass					
700	700.000	699.100	-0.900	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	3611011	MAL 26031229	06-03-2026

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 14-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Authorized Signatory,

Ivan Pusan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person