

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0647-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAB10CT010	Range	0 ~ 700
Instrument Description	IP TURBINE REHEAT BOWL UPPER OUTER METAL TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	7 °C
Serial Number	-	Cal. Date	28-05-2024
Instrument Location	TURBINE 3RD FLOOR	Temp. Element	Thermocouple Type K

Environment Condition

Temperature	31.4 °C	DCS Reading	43.6 °C
Humidity	54 % RH	Actual Reading	43.2 °C

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.100	-0.900	Pass					
175	175.000	174.100	-0.900	Pass					
350	350.000	349.000	-1.000	Pass					
525	525.000	524.000	-1.000	Pass					
700	700.000	699.000	-1.000	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022

Calibration Method

0012/SOP_BJS/2023
 Loop Check Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi


Approved Signatory,

HERVITAMA



M. Taufiqul Fikriyan

Calibrated by,



Khajib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

