

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0922-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAB10CT045
Instrument Description IP TURBINE LOWER INNER METAL GENERATOR SIDE EXHAUST
TEMPERATURE
Manufacture YAMARI
Model / Serial Number - / -
Instrument Location TURBINE 3RD FLOOR

Range 0 ~ 700
Unit °C
Out. Signal 4 - 20 mA
Max. Deviation 7 °C
Cal. Date 13-06-2026
Temp. Element Thermocouple Type K

Environment Condition

Temperature 25.9 °C Humidity 73 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-1.000	-1.000	Pass					
175	175.000	174.300	-0.700	Pass					
350	350.000	349.400	-0.600	Pass					
525	525.000	524.500	-0.500	Pass					
700	700.000	699.600	-0.400	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description DOCUMENTING PROCESS
CALIBRATOR FLUKE 754
Serial Number 3611011
Certificate Number MAL 26031229
Calibration Date 06-03-2026

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 14-06-2026

Customer Signature,

Ayron Humardani Putradhi

HERVITAMA



INDONESIA
Ivan Prasasti Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person