

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0926-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60MAC10CT005

LP TURBINE A EXHAUST HOOD TURBINE SIDE TEMPERATURE 1

YAMARI

- / 5392885

TURBINE 3RD FLOOR

Range

Unit

Out. Signal

Max. Deviation

Cal. Date

Temp. Element

0 ~ 150

°C

4 - 20 mA

1.7 °C (JIS)

11-06-2026

Thermocouple Type E

Environment Condition

Temperature

28,8 °C

Humidity

76 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.900	0.300	Pass					
60	59.600	60.100	0.500	Pass					
90	89.900	90.500	0.600	Pass					
120	119.700	121.100	1.400	Pass					
150	150.200	151.200	1.000	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

DOCUMENTING PROCESS
CALIBRATOR FLUKE 754

3611011

MAL 26031229

06-03-2026

DRY WELL CALIBRATOR ADDITEL
875

660TH19040016

S-25010822

22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 14-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signature,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

