

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0932-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAC20CT005
 Instrument Description LP TURBINE B EXHAUST HOOD TURBINE SIDE TEMPERATURE 1
 Manufacture YAMARI
 Model / Serial Number - / 5392891
 Instrument Location TURBINE 3RD FLOOR

Range 0 ~ 150
 Unit °C
 Out. Signal 4 - 20 mA
 Max. Deviation 1.7 °C (JIS)
 Cal. Date 11-06-2026
 Temp. Element Thermocouple Type E

Environment Condition

Temperature 29,1 °C Humidity 74 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	39.600	40.000	0.400	Pass					
60	59.600	60.100	0.500	Pass					
90	89.900	90.500	0.600	Pass					
120	119.700	120.100	0.400	Pass					
150	150.200	151.200	1.000	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
 Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	3611011	MAL 26031229	06-03-2026
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025
 Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
 Date of issue, 14-06-2026

Customer Signature,

Ayrton Humardani Putradhi

Approved by,

INDONESIA
 Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person