

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0664-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60MAC20CT015	Range	0 ~ 150
Instrument Description	LP TURBINE B EXHAUST HOOD TURBINE SIDE TEMPERATURE 3	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	-	Max. Deviation	1.7 °C (JIS)
Serial Number	5392893	Cal. Date	21-05-2024
Instrument Location	TURBINE 3RD FLOOR	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 26.4 °C  
Humidity 65 % RH

### Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.010	40.100	0.090	Pass					
60	60.000	60.500	0.500	Pass					
90	90.000	90.700	0.700	Pass					
120	120.000	120.800	0.800	Pass					
150	150.000	151.000	1.000	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023

### Calibration Method

0002/SOP\_BJS/2023  
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
Date of issue, 22-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Pihyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

