CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0937-26-HI-CAL-10

Customer Information

Company Name	PT. Bhumi Jati Power
Address	PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.	C-BJP-26-0004-OTH

Instrument Information

KKS No.	60MAC20CT030	Range	0 ~ 150
Instrument Description	LP TURBINE B EXHAUST HOOD GENERATOR SIDE TEMPERATURE 3	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model / Serial Number	- / 5392896	Max. Deviation	1.7 °C (JIS)
Instrument Location	TURBINE 3RD FLOOR	Cal. Date	11-06-2026
		Temp. Element	Thermocouple Type E

Environment Condition

Temperature	29.3 °C	Humidity	75 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input [°C]	Std Output [°C]	Output UUT [°C]	Deviation	Result	Input [°C]	Std Output [°C]	Output UUT [°C]	Deviation	Result
40	39.600	39.900	0.300	Pass					
60	59.600	60.100	0.500	Pass					
90	89.900	90.600	0.700	Pass					
120	119.700	121.200	1.500	Pass					
150	150.200	151.100	0.900	Pass					

Visual Inspection (Checklist if OK)

Leak Check	☐	Tightness Check	☑	Corrosion Check	☑
Accessories Check	☑	Power Supply	☐		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	3611011	MAL 26031229	06-03-2026
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 14-06-2026

Customer Signature,	Approved Signatory,	Calibrated by,
Ayrton Humardani Putradhi	Iqbal Hesbi Ashari	Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia
**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*
This certificate is valid if it has approved and signed by authorized person