

CERTIFICATE OF CALIBRATION

TEMPERATURE SENSOR

Certificate No. : 0668-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAC20CT035	Range	0 ~ 400
Instrument Description	LP TURBINE LAST STAGE BLADE A TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4-20 mA
Model	-T	Max. Deviation	4 °C
Serial Number	-T	Cal. Date	20-05-2024
Instrument Location	TURBINE 3rd FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 32.1 °C
Humidity 54 % RH

Calibration Result

Data Reading				
As Found			As Left	
Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]		
40	40.000	39.300	-0.700	Pass
100	100.000	99.300	-0.700	Pass
200	200.000	199.500	-0.500	Pass
300	300.000	299.500	-0.500	Pass
400	400.000	399.500	-0.500	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 21-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

