

CERTIFICATE OF CALIBRATION

TEMPERATURE SENSOR

Certificate No. : 0939-26-HI-CAL-10

Customer Information

Company Name

PT. Bumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60MAC20CT040

Instrument Description

LP TURBINE LAST STAGE BLADE B TEMPERATURE

Manufacture

YAMARI

Model / Serial Number

-/-

Instrument Location

TURBINE 3rd FLOOR

Range

0 ~ 400

Unit

°C

Out. Signal

4-20 mA

Max. Deviation

4 °C

Cal. Date

30-06-2026

Temp. Element

Thermocouple Type E

Environment Condition

Temperature

30.1 °C

Humidity

51 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
0	0.000	-0.900	-0.900	Pass					
100	100.000	99.300	-0.700	Pass					
200	200.000	199.40	-0.600	Pass					
300	300.000	299.500	-0.500	Pass					
400	400.000	399.600	-0.400	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Temperature Calibrator Fluke 725

Serial Number

2815000

Certificate Number

2256/25/KAL/06/2025

Calibration Date

23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of Issue, 01-07-2026

Customer Signature,

Ayton Humardani Putradhi

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person