

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0675-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAD10CT025	Range	0 ~ 150
Instrument Description	TURBINE BEARING NO.7 METAL TEMPERATURE	Unit	°C
Manufacture	YAMARI	Out. Signal	4-20 mA
Model	-	Max. Deviation	1.7 °C (JIS)
Serial Number	-	Cal. Date	20-05-2024
Instrument Location	TURBINE 3rd FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 31.9 °C
Humidity 54 % RH

Calibration Result

Data Reading				
As Found			As Left	
Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]		
40	40.000	39.400	-0.600	Pass
60	60.000	59.400	-0.600	Pass
90	90.000	89.400	-0.600	Pass
120	120.000	119.500	-0.500	Pass
150	150.000	149.500	-0.500	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 21-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

