

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0172-24-HI-CAL-101

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60MAG10CL005	Range	NWL-700 ~ NWL+500
Instrument Description	CONDENSER HOT WELL LEVEL 1	Unit	mm
Manufacture	TOKYO KEISO	Out. Signal	4 - 20 mA
Model	FST 4512	Max. Error	0.5 %
Serial Number	L19-10464-6-1	Cal. Date	28-05-2024
Instrument Location	TURBINE UNDERGROUND		

Environment Condition

Temperature: 33 °C
Humidity: 43 % RH

Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-700	-700	-696	4.000	4.060	0.060	0.375	Pass								
-400	-400	-409	8.000	7.960	-0.040	-0.250	Pass								
-100	-100	-104	12.000	11.950	-0.050	-0.313	Pass								
200	200	200	16.000	15.990	-0.010	-0.063	Pass								
500	500	501	20.000	20.000	0.000	0.000	Pass								

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
Date of issue, 29-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Yudianto Nurfitriyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

***Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang**

This certificate is valid if it has approved and signed by authorized person

