

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0173-24-HI-CAL-101

Customer Information

Company Name: PT. Bumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60MAG10CL010 Range: **NWL-700 - NWL+500**
Instrument Description: CONDENSER HOT WELL LEVEL 2 Unit: **mm**
Manufacture: TOKYO KEISO Out. Signal: **4 - 20 mA**
Model: FST 4512 Max. Error: **0.5 %**
Serial Number: L19-10464-6-2 Cal. Date: **28-05-2024**
Instrument Location: TURBINE UNDERGROUND

Environment Condition

Temperature: 35 °C
Humidity: 48 % RH

Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-700	-700	-696	4.000	4.050	0.050	0.313	Pass								
-400	-400	-403	8.000	7.960	-0.040	-0.250	Pass								
-100	-100	-104	12.000	11.950	-0.050	-0.313	Pass								
200	200	200	16.000	15.990	-0.010	-0.063	Pass								
500	500	501	20.000	20.000	0.000	0.000	Pass								

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0009/SOP_BJS/2023
Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Teddy Nugroho

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

#Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

