

CERTIFICATE OF CALIBRATION
LEVEL TRANSMITTER

Certificate No. : 1136-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60MAG10CL010 Range -700 ~ 500
Instrument Description CONDENSER HOT WELL LEVEL 2 Unit mm
Manufacture TOKYO KEISO Out. Signal 4 - 20 mA
Model / Serial Number FST 4000 / L19-10464-6-2 Max. Error 0.5%
Instrument Location TURBINE UNDERGROUND Cal. Date 08-06-2026

Environment Condition

Temperature 27 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
-700	-606	-625	-	-19.000	-1.583	Fail	-700	-639	-638	4.832	1.000	0.083	Pass
-400	-409	-398	-	11.000	0.917	Fail	-400	-393	-397	8.054	-4.000	-0.333	Pass
-100	-79	-70	-	9.000	0.750	Fail	-100	-88	-86	12.189	2.000	0.167	Pass
200	207	215	-	8.000	0.667	Fail	200	211	212	16.168	1.000	0.083	Pass
500	494	494	-	0.000	0.000	Pass	500	500	501	20.018	1.000	0.083	Pass

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0005/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Transmitter Displacer

This certificate comprises 2 pages
Date of issue, 12-06-2026

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

