

CERTIFICATE OF CALIBRATION LEVEL TRANSMITTER

Certificate No. : 0174-24-HI-CAL-101

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60MAG10CL015 Range NWL-700 ~ NWL+500
 Instrument Description CONDENSER HOT WELL LEVEL 3 Unit mm
 Manufacture TOKYO KEISO Out. Signal 4 - 20 mA
 Model FST 415 Max. Error 0.5 %
 Serial Number L19-10464-6-3 Cal. Date 28-05-2024
 Instrument Location TURBINE UNDERGROUND

Environment Condition

Temperature 35 °C
 Humidity 48 % RH

Calibration Result

Data Reading (Transmitter)															
As Found								As Left							
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]	
-700	-700	-696	4.000	4.050	0.050	0.313	Pass								
-400	-400	-403	8.000	7.960	-0.040	-0.250	Pass								
-100	-100	-104	12.000	11.950	-0.050	-0.313	Pass								
200	200	200	16.000	15.990	-0.010	-0.063	Pass								
500	500	501	20.000	20.000	0.000	0.000	Pass								

Standard Reference

Description Digital Multimeter Fluke 87V Serial Number 49910296 Certificate Number S. 22 008 273 Calibration Date 13-07-2022

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 29-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,
 HERVITAMA



M. Indonesiyan

Calibrated by,



R. Heru Setyo Utomo

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

